

Benjamin Bailey

From: Katherine Waters
Sent: 01 May 2020 16:57
To: Benjamin Bailey
Subject: Egley Road - PLan/2019/1177

Switch-MessageId: 645d46991c8949f49964e16fbaba19a3

Dear Ben,

Thank you for consulting me on the above planning application and the additional information. Following a review the information submitted is sufficient in relation to NPPF and Woking Core Strategy Policy CS9 on flood risk and drainage grounds subject to the following conditions.

“No development shall commence until construction drawings of the surface water drainage network, associated sustainable drainage components, flow control mechanisms and a detailed construction method statement have been submitted to and approved in writing by the Local Planning Authority. The scheme shall then be constructed in accordance with the approved drawings, method statement and Micro drainage calculations prior to the first use of the development hereby approved. No alteration to the approved drainage scheme shall occur without prior written approval of the Local Planning Authority.

Reason: To ensure that the development achieves a high standard of sustainability and to comply with Policies CS9 and CS16 of the Woking Core Strategy 2012 and the policies in the NPPF.”

“Prior to first use of the development hereby approved details of the maintenance and management of the sustainable drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The drainage scheme shall be implemented and thereafter managed and maintained in accordance with the approved details in perpetuity. The Local Planning Authority shall be granted access to inspect the sustainable drainage scheme for the lifetime of the development. The details of the scheme to be submitted for approval shall include:

- I. a timetable for its implementation,
- II. details of SuDS features and connecting drainage structures and maintenance requirement for each aspect
- III. a table to allow the recording of each inspection and maintenance activity, as well as allowing any faults to be recorded and actions taken to rectify issues; and
- IV. a management and maintenance plan for the lifetime of the development which shall include the arrangements for adoption by any public body or statutory undertaker, or any other arrangements to secure the operation of the sustainable drainage scheme throughout its lifetime.

Reason: To ensure that the development achieves a high standard of sustainability continues to be maintained as agreed for the lifetime of the development and to comply with Policies CS9 and CS16 of the Woking Core Strategy 2012 and policies in the NPPF.”

“ Prior to first use of the development hereby approved a verification report, (appended with substantiating evidence demonstrating the approved construction details and specifications have been implemented in accordance with the surface water drainage scheme), has been submitted to and approved (in writing) by the Local Planning Authority. The verification report shall include photographs of excavations and soil profiles/horizons, any installation of any surface water structure and Control mechanism.

Reason: To ensure that the development achieves a high standard of sustainability and to comply with Policies CS9 and CS16 of the Woking Core Strategy 2012 and the policies in the NPPF.”

Kind Regards

Katherine Waters
Drainage and Flood Risk Engineer

Woking Borough Council, Civic Offices, Gloucester Square, Woking, Surrey, GU21 6YL

T: +44 (0)1483 743725 | www.woking.gov.uk

For general enquiries, please call Woking Borough Council's Contact Centre on 01483 755855